



I-BUS
meters

Width : 2.40
Track : 2.40
Lock to Lock Time : 6.0
Steering Angle : 39.3

DESIGN FIRE FLOW
= 225 l/s
MIN. FIRE FLOW PRESSURE
= 20 PSI

LEGEND	
	PROPOSED EDGE OF PAVEMENT
	PROPOSED WATERMAIN
	PROPOSED FIRE HYDRANT
	PROPOSED GATE VALVE

No.	DESCRIPTION	BY	DATE
1	ISSUED FOR BUILDING PERMIT	DWF	APR02/19
REVISIONS			

P.Eng.

ISL Engineering and Land Services
 #201, 8506 - 200 STREET
 Langley, B.C. V2Y 0M1
 Office: (604) 371-0091
 Fax: (604) 371-0098
 www.islengineering.com

Scale
1: 750

FRASER GRAIN TERMINAL
 NEW GRAIN EXPORT FACILITY
 11041 ELEVATOR ROAD, SURREY

Drawn: DWF Design Checked: **SJV** Date: **MAR 2018**
 Designed: DWF Discipline Review: **SJV** Date: **MAR 2018**

FIRE LOOP
PLAN

Drawing No.
32022 C-21
Sheet No.
29